



INGREDIENTS LIST
Living Building Challenge 4.0

Dated: 01/12/2026

CONTACT INFORMATION		MANUFACTURING FACILITY INFORMATION	
Name of Person Completing Form:	Tiffany Dunworth	Company Name:	Picoma
Company:	Wheatland Tube/Zekelman	Street Address:	9208 Jeffrey Drive
Title:	Technical Services Manager	City, State, Zip code:	Cambridge, OH 43725
Telephone:	724-342-6851 x 8441	Country:	United States of America
Email:	Tiffany.Dunworth@Zekelman.com	Website:	www.picoma.com
		Telephone:	800-picoma1

PRODUCT INFORMATION	
Product Trade Name:	Galvanized Steel Conduit Products (Rigid Conduit and EMT Elbows, Couplings & Nipples (ECNs))
Product Description / Type:	1/2" through 6" Galvanized Conduit Products
Product Website:	www.Picoma.com
Volatile Organic compounds (VOC) level (if wet-applied):	Not Applicable

Ingredient Name (chemical name)	CAS (Chemical Abstract Services) Number (if applicable)	PPM Value (where restricted)	% of Total Product (by weight)	Threshold Requirement
RoHS (Reduction of Hazardous Substances) / LBC (Living Building Challenge) Red List Restricted Substances				
Cadmium (Cd)	7440-43-9	<1000 ppm	Trace	< 100 ppm (0.01%) (RoHS 2)
*Lead (Pb)	7139-92-1	<1000 ppm	Trace	*exempt per RoHS Annex III Lead Exemptions / not restricted on LBC Red List
Mercury (Hg)		zero (0) ppm	0%	< 1000 ppm (0.1%) (RoHS 2)
Hexavalent Chromium (Cr VI)	7789-06-2	<100 ppm	</= 0.01 %	< 1000 ppm (0.1%) (RoHS 2) / <100 ppm (Red List)
Hexavalent Chromium (Cr 6+)	18540-29-9	<100 ppm	</= 0.01 %	< 1000 ppm (0.1%) (RoHS 2) / <100 ppm (Red List)
Polybrominated Biphenyls (PBB)		zero (0) ppm	0%	< 1000 ppm (0.1%) (RoHS 2)
Polybrominated Diphenyl Ethers (PBDE)		zero (0) ppm	0%	< 1000 ppm (0.1%) (RoHS 2)
Bis(2-Ethylhexyl) phthalate (DEHP)		zero (0) ppm	0%	< 1000 ppm (0.1%) (RoHS 3)
Benzyl butyl phthalate (BBP)	85-68-7	<100 ppm	</= 0.01 %	< 1000 ppm (0.1%) (RoHS 3) / <100 ppm (Red List)
Dibutyl Phtalate (DBP)	84-74-2	<100 ppm	</= 0.01 %	< 1000 ppm (0.1%) (RoHS 3) / <100 ppm (Red List)
Diisobutyl phthalate (DIBP)		zero (0) ppm	0%	< 1000 ppm (0.1%) (RoHS 3)
PROPRIETARY INGREDIENTS LIST (if not listed above)				
Proprietary Ingredients		-	0%	not applicable
NON-PROPRIETARY INGREDIENTS LIST (if not listed above)				
Iron (Fe)	7439-89-6	>896500	> 89.65 %	not restricted
Aluminum (Al)	7429-90-5	≤ 700	≤ 0.070 %	not restricted
Carbon (C)	7440-44-0	≤ 4600	≤ 0.46 %	not restricted
*Chromium (Cr)	7440-47-3	≤ 1000	≤ 0.10 %	*not restricted, not intentionally added
Copper	7440-50-8	≤ 2100	≤0.21 %	not restricted
Manganese	7439-96-5	≤ 16600	≤ 1.66 %	not restricted
Molybdenum	7439-98-7	≤ 2500	≤ 0.25 %	not restricted
*Nickel	7440-02-0	≤ 1000	≤ 0.10 %	*not restricted, not intentionally added
Silicon	7440-21-3	≤ 3500	≤ 0.35 %	not restricted
Vanadium	7440-62-2	≤ 1500	≤ 0.15 %	not restricted
Zinc (Galvanized & Conduit products)	7439-98-7	≤ 60000	≤ 6.0 %	not restricted
Total Ingredient List =			100%	

RoHS stands for Reduction of Hazardous Substances. Picoma's galvanized conduit products comply with the RoHS requirements. Cadmium is a naturally occurring impurity in the SHG zinc that we use and is not intentionally added. Nickel and Chromium are residual elements in the steel we purchase and are not intentionally added. RoHS Lead 0.1% content is exempted when used as an alloying element in steel per RoHS Annex III Lead Exemptions. As stated above, these products are below the applicable maximum threshold limits, determined by RoHS and the LBC Red List CASRN Guide.

If I can be of any further assistance, please do not hesitate to contact me.

Sincerely,

Tiffany Dunworth
Technical Services Manager